



6/10/2022

Guru Teg Bahadur Public School. Chandigarh Sector 15

- (a) I have visited the above mentioned school on 25/03/2022 whose cover area is 2264 sq.m whereas it was mentioned earlier as 1810.24 sq.m. which was a typographical mistake as per measurements. I have visually inspected it from all angles of safety and I found it **Safe** for normal use as a school building.
- (b) In case of addition /alteration or expansion and modification of (this building is to be carried out) the same to be carried out under the supervision of technically qualified Engineer and this certificate again be obtained after the completion from the undersigned.
- (c) In case additional extension of **overhead water tank more than eight thousand** litres capacity may be not safe for the building so requested to avoid more weight on roof. (Already water tank has been set 2000+2000+2000 i.e 6000 litres)
- (d) In case the building is effected by flood or if there is settlement of walls/foundations or sagging of roof etc. immediately inspection of the undersigned be arranged to check the stability and safety of the building.
- (e) This building can safely be occupied for normal use upto (indicate year upto which it can be used) **April 2022 to April 2050.**

Anita
1/17/22

PRINCIPAL
Guru Teg Bahadur Public School
Sector 15-C, Chandigarh

[Signature]
30.6.22

CHAIRMAN
Managing Committee
G.T.B. Public School
Sector 15-C, Chandigarh

For KMA Architecture:

[Signature]

(Mrs. Anita Khanna)
Authorised Engineer

Er. Anita Khanna
ME (Structures) IIIT(R)
H. No. 113, Sector 27-A, Chandigarh