



# MUNICIPAL CORPORATION CHANDIGARH

## Public Health Laboratory at Water Works Sector - 39

### TEST - REPORT

Not for legal use

Ref. No. & Date :- No GTPBS/CHD/0038/2023-24 dated 27.02.2024  
 Issued to :-  The Principal  
 :- Guru Teg Bahadur Public School  
 :- Sector - 15 - C, Chandigarh  
 Quantity of sample :- Approximate 1200 ml.  
 Date of Collection :- 29-02-2024  
 Client reference :- Sample Collected by Laboratory Staff  
 Packing of sample :- Sample Filled in P.P. and Glass Bottle  
 Source of sample :- from School tap of Guru Teg Bahadur Public School  
 Sector - 15 - C, Chandigarh


S.No.	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	-----	7.72
2	Turbidity	< 1.0	mg/l	0.8
3	Residual Chlorine	0.2 - 0.4	mg/l	0.2
4	Total Alkalinity (as CaCO <sub>3</sub> )	< 200	mg/l	102
5	Total Hardness (as CaCO <sub>3</sub> )	< 200	mg/l	80
6	Chloride (as Cl)	< 250	mg/l	04
7	Free & Saline Ammonia	Nil	mg/l	NIL
8	Total Dissolved Solids	< 500	mg/l	144
9	M.P.N. of Coliform Bacilli / 100ml of water	Zero	M.P.N.	0 (Excellent)


Payment received vide receipt No.02/2023-24/180456, dated 20.02.2024, Amount Rs.3300/-

Note:- Water is fit for drinking

Lab No.- MCPHL/24/ ... 818


Dated:- 02.03.2024


  
 Chemist  
 M.C.P.H. Laboratory  
 Chandigarh


  
 Sub Divisional Engineer,  
 M.C.P.H. Sub Division No.1  
 Chandigarh  
 Dated :- .....


Endst No. MCPH/24/.....

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh  
 For Information Please.

  
 Chemist  
 M.C.P.H. Laboratory  
 Chandigarh

  
 Sub Divisional Engineer,  
 M.C.P.H. Sub Division No.1  
 Chandigarh

  
 1/4/24  
 PRINCIPAL  
 Guru Teg Bahadur Public School  
 Sector - 15 - C, Chandigarh

  
 CHAIRMAN  
 Managing Committee  
 G.T.B. Public School  
 Sector 15-C, Chandigarh