



# MUNICIPAL CORPORATION CHANDIGARH

Public Health Laboratory at Water Works Sector - 39

## TEST - REPORT

Not for legal use

Ref. No. & Date : - No.Nil dated: 12.03.2025  
Issued to : - The Principal  
: - Guru Teg Bahadur Public School  
: - Sector - 15,C, Chandigarh  
Quantity of sample : - Approximate 1200 ml.  
Date of Collection : - 19-03-2025  
Client reference : - Sample Collected by Laboratory Staff  
Packing of sample : - Sample filled in P.P. and Glass Bottle  
Source of sample : - from School tap of Guru Teg Bahadur Public School  
Sector - 15,C, Chandigarh

S.No.	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	----	7.67
2	Odour	Agreeable	----	Agreeable
3	Taste	Agreeable	----	Agreeable
4	Turbidity	< 1.0	N.T.U.	0.9
5	Residual Chlorine	0.2 - 0.4	mg/l	0.2
6	Total Alkalinity (as CaCO <sub>3</sub> )	< 200	mg/l	108
7	Total Hardness (as CaCO <sub>3</sub> )	< 200	mg/l	86
8	Chloride (as Cl )	< 250	mg/l	06
9	Free & Saline Ammonia	NIL	mg/l	NIL
10	Total Dissolved Solids	< 500	mg/l	152
11	M.P.N. of Coliform Bacilli Per 100ml of water	Zero	M.P.N.	0 (Excellent)

Payment received videreceipt No.03/2024-25/238926, dated 18.03.2025, Amount Rs.3300/-

**Note: Water is fit for drinking.**

Lab No.- MCPHL/25/ 919

Dated:- 22.03.2025

*[Signature]*  
Chemist  
M.C.P.H. Laboratory  
Chandigarh

*[Signature]*  
Sub Divisional Engineer,  
M.C.P.H. Sub Division No.1  
Chandigarh

Dated :-22.03.2025

Endst No. MCPH/25/.....

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh  
For Information Please.

*[Signature]*  
CHAIRMAN  
Managing Committee  
G.T.B. Public School  
Sector 15-C, Chandigarh

*[Signature]*  
Chemist  
M.C.P.H. Laboratory  
Chandigarh

*[Signature]*  
Sub Divisional Engineer,  
M.C.P.H. Sub Division No.1  
Chandigarh

*[Signature]*  
PRINCIPAL  
Guru Teg Bahadur Public School  
Sector 15-C, Chandigarh