



MUNICIPAL CORPORATION CHANDIGARH

Public Health Laboratory at Water Works Sector - 39

TEST - REPORT

Not for legal use

Ref. No. & Date :- No. Nil dated: 12.03.2025
 Issued to :- The Principal
 :- Guru Teg Bahadur Public School
 :- Sector - 15, C, Chandigarh
 Quantity of sample :- Approximate 1200 ml.
 Date of Collection :- 19-03-2025
 Client reference :- Sample Collected by Laboratory Staff
 Packing of sample :- Sample filled in P.P. and Glass Bottle
 Source of sample :- from School tap of Guru Teg Bahadur Public School
 Sector - 15, C, Chandigarh

S.No.	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	---	7.67
2	Odour	Agreeable	---	Agreeable
3	Taste	Agreeable	---	Agreeable
4	Turbidity	< 1.0	N.T.U.	0.9
5	Residual Chlorine	0.2 - 0.4	mg/l	0.2
6	Total Alkalinity (as CaCO ₃)	< 200	mg/l	103
7	Total Hardness (as CaCO ₃)	< 200	mg/l	86
8	Chloride (as Cl)	< 250	mg/l	06
9	Free & Saline Ammonia	NIL	mg/l	NIL
10	Total Dissolved Solids	< 500	mg/l	152
11	M.P.N. of Collform Bacilli Per 100ml of water	Zero	M.P.N.	0

(Excellent)

Payment received videreceipt No.03/2024-25/238926, dated 18.03.2025, Amount Rs.3300/-

Note: Water is fit for drinking.

Lab No.- MCPHL/25/ 919

Dated:- 22.03.2025

[Signature]
 Chemist
 M.C.P.H. Laboratory
 Chandigarh

[Signature]
 Sub Divisional Engineer,
 M.C.P.H. Sub Division No.1
 Chandigarh

Dated:-22.03.2025

Endst No. MCPH/25/.....

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh For Information Please.

[Signature]
 CHAIRMAN
 Managing Committee
 G.T.B. Public School
 Sector 15 C, Chandigarh

[Signature]
 PRINCIPAL
 Guru Teg Bahadur Public School
 Sector 15-C, Chandigarh

[Signature]
 Sub-Divisional Engineer,
 M.C.P.H. Sub Divi
 Chandigarh